



GOVERNMENT OF TAMIL NADU

DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated 23.09.2024 on the basis of affidavit by the applicant)

Certificate Number : TN00126CBE50326

Issued Date : 02-09-2026

Organization Type : Educational Institutions

Expiry Date : 01-09-2027

Name of the Organization : K G INTERNATIONALSCHOOL

Address : 263/1 ALLIKARANPALAYAM ODDERPALAYAM VILLAGE

ODDERPALAYAM POST ANNUR COIMBATORE

I, G RAMASAMY owner/manager of the K G INTERNATIONALSCHOOL functioning as Educational Institutions located at Odderpalayam, in Coimbatore district hereby declare that

- This Self-Declared Sanitation certificate is valid from 02-09-2026 to 01-09-2027 and will be renewed every year prior to the expiry of the current certificate with updated information.
- Our premises can accommodate 2380 people/pupils and has 120 urinals and 102 toilets which is proportionate to the number of users as per government norms.
- 3 Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
- The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
- There is no potential mosquito breeding area on the premises.
- The premises have adequate drinking water fountains on each floor of the premises.
- The self-declared certificate is displayed prominently on the premises along with the protocol

The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.

Signature of the Owner/Manager



(அ) TN00126CBE50326 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/> ல் உள்ளீடு செய்து சரிபார்க்கவும்.

(அல்லது)

(ஆ) கைப்பேசியில் பார்ப்பதற்கு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.

Genuineness of the certificate can be verified by.

(a)Keying in the unique certificate number TN00126CBE50326 in the URL

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/>

(or)

(b)Reading the 2D barcode with mobile barcode reader and verify through online.



**TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
DISTRICT WATER TESTING LABORATORY**

**TWAD Board, Siruvani Nagar Campus., 30, Bharathi Park Road,
Coimbatore - 641043.**

Phone: 0422 - 2437863

E-mail: twadlabce@gmail.com



TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/ 52470 -1	Report Issue Date :	18.11.2025	Page No : 1 of 1
Invoice Details:	9541/Dt.13.11.2025/ Amt.1652/-	ULR No : - NA -		

Client Name & Address		: K.G. International School, Allikarampalayam, Oddarpalayam, Annur.				
Contact No / Email.ID						
Sample / Lab No	:	2025/52470				
Sample Name	:	Water - Drinking Water				
Sample Description	:	Clear, Colorless, Liquid				
Sample Source	:	Tap Water				
Sample Submitted by	:	Customer				
Location & Date	:	Near Reception Area, Annur, Coimbatore & 13.11.2025				
Sample Container	:	Plastic – Good Condition				
Quantity of Sample Received	:	2 Litre	Sample Condition on Receipt	:	Good	
Sample Received on	:	13.11.2025	Environmental Condition Temp °C	:	23 – 27 °C	
Test Commenced on	:	13.11.2025	Test Completed on	:	14.11.2025	
S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25°C	--	IS 3025: Part 11: 2022	7.1	6.5-8.5	No Relaxation
2	Total Hardness as CaCO ₃	mg/L	IS 3025: Part 21: 2009 (RA:2023)	30	200	600
3	Total Alkalinity as CaCO ₃	mg/L	IS 3025: Part 23: 2023	26	200	600
4	Chloride as Cl	mg/L	IS 3025: Part 32: 1988 (RA:2019)	14	250	1000
5	Sulphate as SO ₄	mg/L	IS 3025: (Part 24/Sec 1): 2022 – Turbidity Method	9	200	400
6	Nitrate as NO ₃	mg/L	IS 3025: (Part 34/Sec-1): 2023 – Screening Method	5	45	No Relaxation
7	Fluoride as F	mg/L	IS 3025: (Part 60/Sec-1): 2023 - SPADNS Method;	< 0.2	1.0	1.5

---End of Report----


Reviewed and Authorised by
P. Gopalan - Assistant Water Analyst
 Assistant Water Analyst
 TWAD Board, DWTL Lab,
 Coimbatore

- The test results relate only to the items tested.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- The test items will not be retained for more than 15 days from the date of issue of the test report.
- The result applied to the sample as received basis.

Issue N / Date	01/01.09.2024	Amend .No / Date	00/-	Page No	1 of 1
----------------	---------------	------------------	------	---------	--------



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
DISTRICT WATER TESTING LABORATORY
TWAD Board, Siruvani Nagar Campus., 30, Bharathi Park Road,
Coimbatore - 641043.

Phone: 0422 - 2437863

E-mail: twadlabce@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/ 52470 - 2	Report Issue Date :	18.11.2025	Page No : 1 of 1
Invoice Details:	9541/Dt.13.11.2025/ Amt.1652/-			

Client Name & Address		: K.G. International School, Allikarampalayam, Oddarpalayam, Annur.		
Contact No / Email.ID				
Sample / Lab No	:	2025/52470		
Sample Name	:	Water - Drinking Water		
Sample Description	:	Clear, Colorless, Liquid		
Sample Source	:	Tap Water		
Sample Submitted by	:	Customer		
Location & Date	:	Near Reception Area, Annur, Coimbatore & 13.11.2025		
Sample Container	:	Plastic – Good Condition		
Quantity of sample Received	:	2 Litre	Sample Condition on Receipt	: Good
Sample Received On	:	13.11.2025	Environmental Condition Temp °C	: 23 – 27 °C
Test Commenced on	:	13.11.2025	Test Completed on	: 14.11.2025

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Turbidity	NTU	IS 3025: Part 10: 2023	< 0.5	1	5
2	Total Dissolved Solids	mg/L	IS 3025: Part 16: 2023	90	500	2000
3	EC @ 25°C	µS/cm	IS 3025: Part 14: 2013	133	--	--
4	P- Alkalinity as CaCO ₃	mg/L	IS 3025: Part 23: 2023	Nil	--	--
5	Calcium as Ca	mg/L	IS 3025: Part 40: 1991	6	75	200
6	Magnesium as Mg	mg/L	IS 3025: Part 46: 2023	4	30	100
7	Sodium as Na	mg/L	IS 3025: Part 45: 2024	13	--	--
8	Potassium as K	mg/L	IS 3025: Part 45: 2024	1	--	--


Reviewed and Authorised by
P. Gopalan - Assistant Water Analyst
Assistant Water Analyst
TWAD Board, Siruvani Nagar Campus., 30, Bharathi Park Road,
Coimbatore

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. The test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
DISTRICT WATER TESTING LABORATORY
TWAD Board, Siruvani Nagar Campus., 30, Bharathi Park Road,
Coimbatore - 641043.

Phone: 0422 - 2437863

E-mail: twadlabcbce@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/ 52470 - 2	Report Issue Date :	18.11.2025	Page No : 2 of 1
Invoice Details:	9541/Dt.13.11.2025/ Amt.1652/-			

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
9	Iron as Fe mg/L	mg/L	IS 3025 (Part 53) : 2024	< 0.1	0.3	No Relaxation
10	Manganese as Mn	mg/L	IS 3025 (Part 59) : 2023	< 0.1	0.1	0.3
11	Ammonia as NH ₃	mg/L	IS 3025 (Part 34) : 2023	0.7	0.5	No relaxation
12	Nitrite as NO ₂	mg/L	IS 3025 (Part 34/Sec-1) : 2023	< 0.01	--	--
13	Phosphate as PO ₄	mg/L	IS 3025 (Part 31/Sec-1) : 2022	< 0.1	--	--
14	Oxygen Observed in 4 hrs.as O ₂ (Tidy's Test)	mg/L	IS 3025 (Part 63) : 2007	0.24	--	--
15	Residual Chlorine	mg/L	IS 3025 (Part 26) : 2007	0	0.2	1.0

Bacteriological Test

1	Fecal Coliform	CFU / 100 ml	APHA 23 rd Edition 2017 – 2130 B	1200	Absent/ 100 ml
---	----------------	--------------	---	------	----------------

Remark: The tested sample does not confirmed to IS: 10500:2012 (RA: 2023) Drinking Water Specification within the permissible Limit in respect to above tested parameters.

---End of Report---


18/11/2025

Reviewed and Authorised by
P. Gopalan - Assistant Water Analyst
 Assistant Water Analyst
 TWAD Board, DWTL Lab,
 Coimbatore

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. The test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

Issue N / Date	01/01.09.2024	Amend .No / Date	00/-	Page No	2 of 2
----------------	---------------	------------------	------	---------	--------